

July 2, 2020


Mag Plus Probe Conformity to OIML R85

Veeder-Root's Mag Plus Probe (Form No. 8463) was initially certified to OIML R85 in August 2009.

There were no substantive changes to the Mag Plus Probes (Form No. 8463) between the introduction in 2002 and the issuance of the OIML R85 Certificate in August 2009. Therefore, we have no reason to believe that Mag Plus Probes manufactured before August 2009 would not be compliant with OIML R85.

The Veeder-Root TLS4xx Consoles and Mag Plus Probes (Form No. 8463) are certified by NMO to OIML R85 Edition 2008. The measuring equipment also meets the OIML D11 2013 performance levels for electrical environmental class E2 for the tests deemed relevant to the equipment by the authors of OIML R85.

Harold E. Findley



Quality Manager
Veeder-Root Company